

Certificate of Conformity

By the product certificate number:

No. 2622/0240-C-CER

Issued to:

License holder:

AISWEI Technology (Shanghai) Co., Ltd.
Room 905B, 757 Mengzi Road, Huangpu District,
200023 Shanghai, P.R. China



Trademark:



Manufacturer:

AISWEI New Energy Technology (YangZhong) Co., Ltd.
No. 588 Gangxing Road, Yangzhong, Zhenjiang, China

It is certified that the product:

Type of generating unit **Grid-connected PV Inverter**

Models: **ASW5000-S ASW6000-S ASW8000-S ASW10000-S**

Technical Data:		ASW5000-S	ASW6000-S	ASW8000-S	ASW10000-S
Nominal power [W]		5000	6000	8000	10000
Nominal voltage [V]		230	230	230	230
Nominal frequency [Hz]		50	50	50	50

Firmware version

Master Software version: V610-01053-04
Slave Firmware version: V610-01054-04
Safety Firmware version: V610-10009-04

Number of phases

Single Phase

Isolation Transformer

No

Is in compliance with the standard:

IEC 62116: 2014

Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters.

This certificate is based upon the test results of the Test Report n° GZES220300424003

The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-18 based on the requirements of the UNE-EN ISO / IEC 17065.

First issued on 31st May 2022

This certificate is valid until 31st May 2027

Madrid, 31st May 2022



Daniel Arranz Muñiz
Certification Manager

