




Product Service

CERTIFICATE

No. Z2 078488 0098 Rev. 00

Holder of Certificate: **Suzhou Talesun Solar Technologies Co., Ltd.**
No. 1 Talesun Road
Shajiabang, Changshu
215542 Suzhou, Jiangsu Province
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062000803-00

Valid until: 2025-06-15

Date, 2020-06-19

(Zhulin Zhang)



CERTIFICATE

No. Z2 078488 0098 Rev. 00

Model(s): TD6G72M-xxx,xxx=395 to 410 in step of 5
 TD6G60M-xxx,xxx=330 to 340 in step of 5
 xxx is standing for rated output power at STC

Parameters:

| | |
|-----------------------------|--|
| Construction: | Framed double glass with Junction box, Cable and Connectors. |
| Safety Class: | Class II |
| Maximum System Voltage: | 1500 V DC |
| Fire Safety Class: | Class C according to UL790 |
| Severity of salt mist test: | Level 6 |

Tested according to:

- IEC 61215-1:2016
- IEC 61215-1-1:2016
- IEC 61215-2:2016
- IEC 61730-1:2016
- IEC 61730-2:2016
- IEC 61701:2011

Production Facility(ies): 078488, 096715